



#2023-06
INVITATION TO BID
FAIRGROUNDS GRANDSTAND ROOF REPLACEMENT
FOR
ROCK COUNTY, WISCONSIN

ADDENDUM #1
QUESTIONS / ROCK COUNTY RESPONSES

Rock County's responses are in **bold** and underlined.

1. Can $\frac{3}{4}$ " plywood be used to patch areas of rotted decking, in lieu of matching the existing tongue and groove plank?
Yes, contractors may utilize 5-ply $\frac{3}{4}$ " plywood to patch areas of rotted decking, provided pieces are installed in sizes necessary to ensure all edges are supported by underlying structural member (if necessary, add additional blocking/bridging between joists to support ends of plywood sheets).
2. I just want to confirm that the new $\frac{1}{4}$ " thick cover board is to be mechanically fastened as specified. After discovering the existing roof deck to be $\frac{3}{4}$ " thick tongue and groove planking at the pre-bid meeting, I believe the fasteners that will hold the cover board in place will extend through the decking and be exposed on the underside. This is not an issue other than aesthetics but I just want to make sure
Yes, the cover board is to be mechanically-fastened, as specified in the project documents.
3. I see the project requires a Performance and Payment Bond. I don't see anything for a bid bond. Is this not going to be required?
Correct, a bid bond is not required.

ROCK COUNTY, WISCONSIN

PURCHASING DIVISION
FINANCE DIRECTOR



#2023-06
INVITATION TO BID
FAIRGROUNDS GRANDSTAND ROOF REPLACEMENT
FOR
ROCK COUNTY, WISCONSIN

ADDENDUM #1
QUESTIONS / ROCK COUNTY RESPONSES

SIGN AND RETURN THIS FORM WITH PROPOSAL.

COMPANY: _____

SIGNATURE: _____

DATE RECEIVED: _____